

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-003867

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|--|--|
| Product | Air Circuit Breaker |
| Name and address of the applicant | Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China |
| Name and address of the manufacturer | Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China |
| Name and address of the factory | Zhejiang Tengen Electric Co., Ltd. (Yueqing Economic Development Zone Branch) No.288 Central Avenue, Development Zone, Yueqing City, 325604 Zhejiang, P.R. China |
| Ratings and principal characteristics | Cat. B; Type of Release: Electronic; 3P, 4P; Ue=AC 415/690V, 50/60Hz; Ui=1000V; Uimp=12.0kV; In: 2500A, 2900A, 3200A, 3600A, 3900A, 4000A; Suitability for Isolation: Yes; Suitability for Using in IT System: Yes; Pollution Degree: 3 |
| Trademark (if any) | Tengen (Logo) |
| Customer's Testing Facility (CTF) Stage used | N/A |
| Model / Type Ref. | TGW1N-4000 ; TGW1N-4000H |
| Additional information (if necessary may also be reported on page 2) | Detailed information refer to test report CN2209U0 001. |
| A sample of the product was tested and found to be in conformity with | IEC 60947-2:2016+A1 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | CN2209U0 001 |

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-04-24

Signature: Wencai Zhang